



## **Evolution of Transmission Systems as Precondition for Decarbonisation of Electricity Supply**

Dr. Matthias Müller-Mienack

Technical Head

International Conference Elements of a Greenhouse Gas Neutral Society  
Berlin, 10th October 2013

## Brief overview on GridLab

# Large-scale disturbance on 04th November 2006

Source:  
50Hertz

**E.ON**  
14 x 380 and  
220kV OHL


**MAVIR**  
4 x 380 kV  
OHL

**APG**  
7 x 380 and 220kV  
OHL

**50,6 Hz** Polen


**49,0 Hz**  
ca. 14500 MW load  
shedding  
10 million customers

**50,2 Hz**



# Squall line „Kyrill“, 18th January 2007

Outage of 5 transmission (double-system) overhead lines (380 and 220 kV)





## ... GridLab establishment as consequence



- **2008:** 50Hertz (TSO for Eastern part of Germany) and the BTU Cottbus started the development of a training center for the dispatching personnel of electricity grid operators with the goal on as real as possible training atmosphere
- **2008-2010:** Development phase with focus on improvement of abilities of dispatching staff of 50Hertz and connected DSOs, and also to assure sufficient recruiting potential for the grid operators
- **December 2010:** Spin-off; foundation of GridLab GmbH in order to provide GridLab services to the overall market for trainings, studies, seminars ...
- **March 2011:** Start of operation with own personnel
- **2013:** GridLab now official associated intitute of the Brandenburg Technical Univ.

# GridLab portfolio at a glance

## Dispatcher Trainings

- Training system for vertical trainings (TSO & DSOs)
- Training system for horizontal trainings (inter-TSO)
- Mobile system for application in customer's locations
- Artificial control area & city grid for virtual trainings



## Studies

- System operation, ancillary services, network planning
- Renewable energy sources integration
- Storage integration, e.g. hydro, power-to-gas/heat
- Consultancy, workshops, expert interviews




## Seminars

- Switching authorization courses 110/380 kV
- Electrically instructed persons
- Basics of energy supply
- Technical Assessment Center, crises management




# The German Energy Turnaround today and tomorrow

# Electricity targets of official German energy concept 2020








# Status quo: Installed RES power vs. German peak load



Source: GridLab; data: Federal Ministry of Environment, "Erneuerbare Energien 2013", February 2013; UCTE/ENTSO-E, "System Adequacy Retrospect" reports; 2000-2012

# Geographical RES spread in Germany




- Wind
- Photovoltaic
- Biomass

Source: 50Hertz, Amprion, Tennet, Transnet BW, Google Earth


# Outlook: Installed RES power in Germany

Acc. to German Network Development Plan for 2023/33 (main scenario)



Source: GridLab; data: 4 German TSOs, German Network Development Plan (official second draft as of July 2013)


# Status quo: RES infeed vs. electricity consumption in Germany



Source: GridLab; data: Federal Min. of Environment, "Entwicklung der erneuerbaren Energien in Deutschland im Jahr 2012", 02/2013

# Outlook: RES infeed share


Contribution of Eastern part of Germany to German Energy Turnaround





# Status quo: Wind infeed in Germany

Squall line end of January 2013




High RES power ramps,  
long-lasting squall lines vs.  
almost no wind infeed periods,  
significant impact on spot price

Source: GridLab;  
data: [www.transparency.eex.com](http://www.transparency.eex.com); [www.eex.com](http://www.eex.com)

# Status quo: PV infeed in Germany


PV infeed 5th June 2013



Source: GridLab; data: [www.transparency.eex.com](http://www.transparency.eex.com); [www.eex.com](http://www.eex.com)

# Impact on installed conventional power

Caused by nuclear phase-out, decreasing peak prices & price spread, ...



Alle heute bekannten Projekte werden realisiert

Alle im Probetrieb, im Bau befindlichen, genehmigte und im Genehmigungsverfahren befindliche Projekte werden realisiert

Nur im Probetrieb, im Bau befindliche und genehmigte Projekte werden realisiert

Nur im Probetrieb und im Bau befindliche Projekte werden realisiert


\* Kernkraftwerke, Kohlekraftwerke, Erdgaskraftwerke, Ölkraftwerke

Quelle: BDEW Stand 05/2013

**To follow-up with decarbonization of electricity supply,  
ancillary services must be ensured  
and more flexibility tools must be made available**

# Operational challenges of RES integration


Ancillary services must be ensured along the decarbonization pathway





# Operational challenges of RES integration


Ancillary services must be ensured along the decarbonization pathway




# Power ramps caused by German RES

Today & tomorrow (based on German Network Development Plan 2023/33)

Maximum power ramps caused by German wind power\* respectively PV power\*\*



Maximum power ramps caused by German wind power\* and PV power\*\*



\* Installed German wind power, average for 2011 was 27,61 GW (source: "Stammdatenbank" of the four TSO's)

\*\* Installed German PV power, average for 2011 was 17,08 GW (source: IWES "Windenergiereport Deutschland 2011")

In 2022 and 2032 the data of the installed power as well as the 1 hour ramps can be found in "Leitszenario (B)" of the NEP (source: plan for the development of the German transmission grid: "Netzentwicklungsplan 2012"). The 1/4 hour ramps for the years 2022 and 2032 are extrapolated by using the maximal ramps per 1/4 hour of 2011 (source: feed-in data of the four German TSO's).


Source: 50Hertz

# Development of reserve power need

Forecast of Leipzig University put in context with German NDP for 2023


## Additional negative reserve power

(- 3 GW as add-on to 2012 value (ca. - 5,1 GW))



## Additional positive reserve power


(+ 5 GW as add-on to 2012 value (ca. + 4.4 GW))



Source: Inka Ziegenhagen, Chair Prof. Bruckner, University of Leipzig, 2013; supplemented by GridLab

# Operational challenges of RES integration

Ancillary services must be ensured along the decarbonization pathway



# Congestion management acc. Energy Act


## Example of unexpected strong squall-line



Source: 50Hertz




### Grid related measures



Special **switching measures** to reduce the power flows on congested lines

### Market related measures



Especially **redipatch measures**: To decrease conventional generation on one side of congested line, and in parallel to increase conventional generation on the other side of congested line in order to reduce the power flow

### Generation curtailment




Once that the conventional generation is reduced to a minimum level still keeping the grid stability, as **local measure** also RES infeed in local areas to be curtailed



As last measure a **global adaptation** of all generations: all RES infeeds in the control area to be curtailed




# Redispatch application with pumped storage power plants




Source:  
VE Hydro

# Pumped storage operation hours

Example for 50Hertz control area in 2011




# Redispatch application of first wind farms




Monitor window of TSO 50Hertz control center for direct adaptation of active power of the windfarm Bertikow also for cross-border redispatch purpose (interconnection to Poland)

# New congestion management tools needed

Power-to-heat/gas to bypass wind energy surplus into other energy markets



# Theoretical power-to-heat-potential of 50Hertz control area of up to 11.8 GW<sub>el</sub> in maximum




Source: Univ. Leipzig/Prof. Bruckner, 50Hertz



# Grid extension as overall measure

German context



22 bn € up to 2023

22 bn € up to 2023



**dena-Verteilnetzstudie.**  
Ausbau- und Innovationsbedarf der Stromverteilnetze in Deutschland bis 2030.



18 bn € up to 2020



# Grid extension as overall measure


European context - 10-Year Network Development Plan of ENTSO-E

**104 bn € up  
to 2022**



# Operational challenges of RES integration

Ancillary services must be ensured along the decarbonization pathway



# Aspect reactive power / voltage control

Increasing reactive power needs esp. caused by nuclear phase-out

Out of BNetzA winter report 2012/2013:

## **Endangered voltage situation in winter 2012/13**

For winter 2012/13, the voltage related risks caused by phase 1 of nuclear phase-out were assumed to be lower than for the previous winter as following measures were realized:


- Conversion of generator of (phased-out) nuclear power station Bilblis A to rotating phase-shifter
- Commissioning of conventional reactive power compensation devices
- Commissioning of new 380 kV line Hamburg-Schwerin

**Nevertheless, esp. from 9th to 10th November 2012 critical voltage situations occurred in Tennet TSO control area (area Emden)....**



# Aspect reactive power / voltage control


First windfarms already controllable by 50Hertz



Monitor window of TSO 50Hertz control center for direct adaptation of voltage value (indirect adaptation of reactive power) for the connection point of the windfarm Bertikow

# Operational challenges of RES integration


Ancillary services must be ensured along the decarbonization pathway



# Aspect Short circuit power / grid stability

Sufficient short circuit power for grid protection schemes as well as inertia for frequency stability required

Source: Univ. Rostock/Prof. Weber




Related the grid structures, this analysis is based on simplified (copper plate) model i.e. real stability problems can be expected with lower share of fluctuating RES power.



# Operational challenges of RES integration

Ancillary services must be ensured along the decarbonization pathway



# Aspect black start and grid restoration

## Extract of 50Hertz grid restoration concept

### Netzwiederaufbau ohne Spannungsvorgabe von benachbarten Übertragungsnetzen


- Teilnetzwiederaufbau ausgehend von thermischen Dampfkraftwerksblöcken im Eigenbedarfsinselbetrieb

KW Rostock  
 KW Reuter West  
 KW Jänschwalde  
 KW Schwarze Pumpe  
 KW Boxberg  
 KW Lippendorf  
 KW Schkopau

- Teilnetzwiederaufbau ausgehend von schwarzstartfähigen Kraftwerken

GTKW Thyrow  
 PSW Markersbach  
 PSW Goldisthal  
 PSW Hohenwarte II

Source: 50Hertz




# The German Energy Turnaround the day after tomorrow

# Outlook: Yield German fluctuating RES


Annual load duration curve

Source: Prognos



# Grid extension as overall measure

Modular Develop. Plan on pan-Europ. Electricity Highways System 2050



Source: ENTSO-e

# There are more dimensions than grid reinforcement/extension ...

**Overall RES in-feed fluctuation (esp. wind, PV)**


**Controllable RES (esp. share of biomass, CSP)**

**Large-scale and decentralised storages**

**Load flexibility (industries, smart homes)**

**Smoothing by inter-continental bulk power links**

**Example:**  
Scenario of 100% RES based electricity system for 2050



Source: ENTSO-e



**Thank you for attention!**

**GridLab GmbH  
Hubertstr. 24  
03044 Cottbus  
GERMANY**

**T +49 (355) 52996801**

**F +49 (355) 52996802**

**W [info@gridlab.de](mailto:info@gridlab.de)**

**[www.gridlab.de](http://www.gridlab.de)**

